

Ladders

| Code | Asset | Finding | Outcome |
|-------|--------------|---|------------------------------------|
| 43001 | 001) Ladders | NON COMPLIANT - Not compliant to AS1657, less than 200mm foot clearance behind ladder, Cage starts at 2.5m, Unequal Rung Spacings, no support brackets to wall - Ladder is very unstable. | NON COMPLIANT PRIORITY 1 |

Recommendations

87 :: Remove non-compliant ladder and Install new angled cage ladder compliant to AS1657.2018

